Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM853

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	NANCY PANZER
Phone #	
Mailing Address	9129 FOREST VIEW ROAD
City	KEWASKUM
State	WI
Zip Code	53040
County	Washington
Co. Permit #	
Notification #	10232927001
Completed	04-21-2026
Well Constructor (Business Name)	GROTH WATER WELLS INC
Lic. #	639
Facility ID # (Public Wells)	
Address	W69 N949 WASHINGTON AVE CEDARBURG WI 53012
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.5

1. Well Location

Town of KEWASKUM

Fire # (if avail.)

Street Address or Road Name and Number: 9129 FOREST VIEW ROAD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.52384 °N -88.161 °W	GPS008

SE	NE	Section	Township	Range
or Govt Lot #		12	12 N	19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	62

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		S	M	Y-YELLOW S-SAND M-SILTY	Surface	26
U		S	C	U-BLUE S-SAND C-CLAYEY	26	50
T	S	S	D	T-TAN/BROWN S-SOFT/LOOSE S-SAND D-W/GLACIAL MATERIAL	50	61
G	W	G		G-GRAY W-WATER BEARING G-GRAVEL/STONES	61	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# ASTM A53 PE WHEATLAND	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
FB	67	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed
SB	8729	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95

Type	Qualifier	Distance
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank		90

Comment:

Created On: 04-24-2026 Updated On: 05-22-2026 Review Status: APPROVED