

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM862		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BOND, JEFF						Phone #									
Mailing Address N3064 COUNTY HWY A						1. Well Location						Fire # (if avail.)			
City COLUMBUS						State WI		Zip Code 53925							
County Columbia		Co. Permit #		Notification # 10234578801		Completed 04-24-2026		Town of OTSEGO				N3064			
Subdivision Name						Lot #		Block #							
Well Constructor (Business Name) WEBSTER & SONS WELL DRILLING, LLC						Lic. # 9242		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3904 °N -89.1435 °W		Method Code GPS008	
Address 415 N. MAIN STREET POYNETTE WI 53955						Well Plan Approval #		NW SW		Section 25		Township 11 N		Range 11 E	
Hicap Permanent Well #						Common Well #		Specific Capacity 0				2. Well Type New Well		of previous unique well # constructed in	
3. Well serves 2 # of HOME AND SHOP						Hicap Well ? No		Private, potable				Reason for replaced or reconstructed well ?		Construction Type Drilled	
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ? No				Reason for replaced or reconstructed well ?		Construction Type Drilled	
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.8		Surface		106		Yes Rotary - Mud Circulation				No					
6		106		164		No Rotary - Air				Yes					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
C		C-CLAY				Surface		7							
Z		Z-CLAY & GRAVEL				7		12							
B L		B-BROKEN L-LIMESTONE/DOLOMITE				12		18							
H L		H-HARD/FIRM L-LIMESTONE/DOLOMITE				18		76							
H N		H-HARD/FIRM N-SANDSTONE				76		90							
N H		N-SANDSTONE H-SHALEY				90		103							
H L		H-HARD/FIRM L-LIMESTONE/DOLOMITE				103		138							
T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				138		164							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND A53B PE .280 WALL				Surface		106							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method BRADENHEAD															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
NEAT CEMENT GROUT		Surface		106		25 S									

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

RW

6890

04-24-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	60
Building Drain - Sanitary	>	75	Ditch or Culvert	>	200
			Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 04-24-2026

Updated On: 05-22-2026

Review Status: APPROVED