Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM862

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOND, JEFF			Phone #
Mailing Address: N3064 COUNTY HWY A			
City: COLUMBUS	State: WI	Zip Code: 53925	
County: Columbia	Co. Permit #	Notification #: 10234578801	Completed: 04-24-2026

Well Constructor (Business Name): WEBSTER & SONS WELL DRILLING, LLC	Lic. #: 9242	Facility ID # (Public Wells)	
Address: 415 N. MAIN STREET POYNETTE WI 53955		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

3. Well serves 2 # of HOME AND SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of OTSEGO				Fire # (if avail.): N3064
Street Address or Road Name and Number: N3064 COUNTY HWY A				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 43.3904 °N -89.1435 °W				Method Code: GPS008
NW SW or Govt Lot #	Section: 25	Township: 11 N	Range: 11 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.8	Surface	106
6	106	164

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

	Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	C			C-CLAY	Surface	7
	Z			Z-CLAY & GRAVEL	7	12
	B	L		B-BROKEN L-LIMESTONE/DOLOMITE	12	18
	H	L		H-HARD/FIRM L-LIMESTONE/DOLOMITE	18	76
	H	N		H-HARD/FIRM N-SANDSTONE	76	90
	N	H		N-SANDSTONE H-SHALEY	90	103
	H	L		H-HARD/FIRM L-LIMESTONE/DOLOMITE	103	138
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	138	164

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B PE .280 WALL	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	106	25 S

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW	6890	04-24-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Drain - Sanitary	>	75

Type	Qualifier	Distance
Sewer - Building Sanitary	>	60
Ditch or Culvert	>	200
Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 04-24-2026 Updated On: 10-15-2026 Review Status: APPROVED