

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM863		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner PRILL, DENNIS					Phone # (920)428-4749			1. Well Location				Fire # (if avail.)				
Mailing Address E6414 COUNTY RD OO								Town of UNION				E6414				
City CLINTONVILLE					State WI		Zip Code 54929					Street Address or Road Name and Number COUNTY RD OO				
County Waupaca		Co. Permit #		Notification # 10145217401			Completed 04-03-2026			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) HINTZKE WELL DRILLING INC					Lic. # 267		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 44.5757 °N -88.9044 °W				Method Code GPS008		
Address N5072 HINTZKE RD NEW LONDON WI 54961-9802					Well Plan Approval #			SE SE		Section 3		Township 24 N		Range 13 E		
								or Govt Lot #								
Approval Date (mm-dd-yyyy)					2. Well Type Replacement											
Hicap Permanent Well #					Common Well #			Specific Capacity 0			of previous unique well # constructed in					
Reason for replaced or reconstructed well ?					POINT FAILING											
3. Well serves 1 # of HOME					Hicap Well ? No			Construction Type Drilled								
Private, potable					Hicap Property ? No											
Heat Exchange ___ # of drillholes					Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock							
6		Surface		460		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
T Y			T-TAN/BROWN Y-SAND & GRAVEL						Surface		42					
T Z			T-TAN/BROWN Z-CLAY & GRAVEL						42		121					
			Q Q-GRANITE						121		460					
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		US NUCORE 280 WALL A53 WELD				Surface		123								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material																
Method MOUNDED																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
GRANULAR BENTONITE				Surface				2 S								
9. Static Water Level																
15 ft. below ground surface																
10. Pump Test																
Pumping level 300 ft. below surface																
Pumping at 12 GP M for 3 Hrs.																
Pumping Method ? Test Pump																
11. Well Is																
24 in. above grade																
Developed ? Yes																
Disinfected ? Yes																
Capped ? Yes																
12. Notified Owner of need to fill & seal ? Yes																
POINT WILL BE FILLED AND SEALED AT TIME OF HOOKUP																
Filled & Sealed Well(s) as needed? Yes																
WEL FILLED AND SEALED 4/24/2026																
13. Constructor / Supervisory Driller				Lic #		Date Signed										
JCH				6935		04-24-2026										
Drill Rig Operator				Lic or Reg #		Date Signed										
GEV				9482		04-24-2026										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50	POWTS dispersal component (soil absorption unit or mound)		65

Comment: FIRST ATTEMPT WELL WAS STOPPED AT 325 FT AND FRACKING WAS UNSUCCESSFUL. WELL WAS THEN DRILLED TO 460 FT AND FRACKED AGAIN

Rehab Type	Rehab Date	Result Text
Hydrofracture	04/03/2026	0 GPM

Created On: 04-24-2026

Updated On: 05-11-2026

Review Status: APPROVED