Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM866

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RADAJ, STEVE	Phone #
Mailing Address: W381 RIVERVIEW DR.	
City: MONTELLO	State: WI — Zip Code: 53949
County: Marquette	Co. Permit #: — Notification #: 10233445401 — Completed: 04-24-2026
Well Constructor (Business Name): WELLS BY WELCH - BENTLEY WD LLC	Lic. #: 7500 — Facility ID # (Public Wells):
Address: 9403 TRI COUNTY RD, FREMONT WI 54940	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 25

1. Well Location

Town of MECAN	Fire # (if avail.): W381
Street Address or Road Name and Number: RIVERVIEW DR.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.803 °N -89.1814 °W	Method Code: OTH001
NE NW or Govt Lot #:	Section: 10 — Township: 15 N — Range: 11 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: REPLACE OLD 2"

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	8
6	8	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	34
		C		C-CLAY	34	52
	Q	N		Q-CAVING N-SANDSTONE	52	66
		N		N-SANDSTONE	66	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, T/C, NUCOR, .280 WALL, ASTMA53B	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: TREMIE PIPE - GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	8	

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 25 GP M for 48 Hrs.

Pumping Method ? Other

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PB	7036	04-29-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RT	5829	04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75

Comment:

Created On: 04-24-2026 Updated On: 10-15-2026 Review Status: APPROVED