

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM871		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner OPALACZ, DENNIS						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 4894 WHITE SWAN DR						Town of SUGAR CAMP						8106			
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number BOARDWALK DR			
County Oneida		Co. Permit #		Notification # 10233951102		Completed 04-22-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) HEDBERG W D/ECS HOLDINGS LLC				Lic. # 6416		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.855 °N -89.41152 °W				Method Code GPS008	
Address PO BOX 1206 EAGLE RIVER WI 54521				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 19 39 N 9 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		51.5		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
T	A	S				T-TAN/BROWN A-COARSE S-SAND				Surface 29					
T	N	S	C			T-TAN/BROWN N-FINE S-SAND C-CLAYEY				29 45					
T	N	X				T-TAN/BROWN N-FINE X-SAND & CLAY				45 48					
T	N	S				T-TAN/BROWN N-FINE S-SAND				48 51.5					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NOVATUBE ASTM A53B 18.97# WELDED				Surface		47.5							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		SS BIGFOOT 8 SLOT				47.5		51.5							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		30		0.75 S									
9. Static Water Level															
19 ft. below ground surface															
10. Pump Test															
Pumping level 39.5 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Test Pump															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
ES				6673		04-22-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-24-2026

Updated On: 05-22-2026

Review Status: APPROVED