Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM871

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OPALACZ, DENNIS	Phone #
Mailing Address: 4894 WHITE SWAN DR	
City: WEST BEND	State: WI — Zip Code: 53095
County: Oneida	Co. Permit #: — Notification #: 10233951102 — Completed: 04-22-2026
Well Constructor (Business Name): HEDBERG W D/ECS HOLDINGS LLC	Lic. #: 6416 — Facility ID # (Public Wells):
Address: PO BOX 1206 EAGLE RIVER WI 54521	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of SUGAR CAMP	Fire # (if avail.): 8106
Street Address or Road Name and Number: BOARDWALK DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.855 °N -89.41152 °W	Method Code: GPS008

SE	NE	Section	Township	Range
or Govt Lot #		19	39 N	9 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	51.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	A	S		T-TAN/BROWN A-COARSE S-SAND	Surface	29
T	N	S	C	T-TAN/BROWN N-FINE S-SAND C-CLAYEY	29	45
T	N	X		T-TAN/BROWN N-FINE X-SAND & CLAY	45	48
T	N	S		T-TAN/BROWN N-FINE S-SAND	48	51.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NOVATUBE ASTM A53B 18.97# WELDED	Surface	47.5
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS BIGFOOT 8 SLOT	47.5	51.5

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	30	0.75 S

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 39.5 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
ES	6673	04-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-24-2026 Updated On: 05-22-2026 Review Status: APPROVED