Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM876

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ELLISON, STEVE AND THERESA	Phone #: (218)360-5949
Mailing Address: 28125 SUNNY BEACH RD	
City: GRAND RAPIDS	State: MN Zip Code: 55744
County: Sawyer	Co. Permit #:
Notification #: 10238777801	Completed: 04-24-2026
Well Constructor (Business Name): KOMAREK, THEODORE	Lic. #: 7003
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: TEAM WELL DRILLING LLC N700 STATE HWY 13 OGEMA WI 54459	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.3	

1. Well Location

Town of WINTER

Fire # (if avail.):

Street Address or Road Name and Number: 5975W GRANDBOUCHE RD

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.9218 °N -90.9833 °W

Method Code: GPS008

SW NW or Govt Lot #: | Section: 27 | Township: 40 N | Range: 5 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable | Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	138

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	Z	C-CLAY Z-W/COBBLES/BOULDERS	Surface	70
		Y	C	Y-SAND & GRAVEL C-CLAYEY	70	77
		M	W	M-SILT W-W/WOOD	77	89
		P		P-HARDPAN	89	135
	E	Y		E-CLEAN Y-SAND & GRAVEL	135	138

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	280 ASTM A53B HT A63664 WELD JT WHEATLAND	Surface	138
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

57 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRK	7003	04-25-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TRK		04-25-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-25-2026 Updated On: 10-15-2026 Review Status: APPROVED