Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM879

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WHALEY, DAN	Phone #
Mailing Address: 2006 LINCOLN AVENUE	
City: ST. PAUL	State: MN Zip Code: 55105

County	Co. Permit #	Notification #	Completed
Burnett		10056668501	04-21-2026

Well Constructor (Business Name): JEREMY BEECROFT WELL DRILLING	Lic. #: 6457
Address: W7414 MILLER RD SPOONER WI 54801	Facility ID # (Public Wells):
	Well Plan Approval #:
	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
	Specific Capacity: 2.7

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of JACKSON

Fire # (if avail.): 5272

Street Address or Road Name and Number: 5272 CTY. RD. C

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.959 °N -92.2642 °W	GPS008

NW NE or Govt Lot #	Section	Township	Range
	18	40 N	15 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	124

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X		X-SAND & CLAY	Surface	30
N	S	M		N-FINE S-SAND M-SILTY	30	90
		X		X-SAND & CLAY	90	105
		Y		Y-SAND & GRAVEL	105	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17PVC CASING WELDED ASTM F480	Surface	119
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	10 SLOT SS SCREEN	119	124

7. Grout or Other Sealing Material
Method TREMIE PIPE- PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	114	8 S

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 75 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	04-26-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JF	8979	04-26-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		60	POWTS dispersal component (soil absorption unit or mound)		70

Comment:

Created On: 04-26-2026 Updated On: 05-22-2026 Review Status: APPROVED