Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM882

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLUCK, RORY	Phone #
Mailing Address: 1609 HUNTERS LANE	
City: GRAFTON	State: WI — Zip Code: 53024
County: Sawyer	Co. Permit #: — Notification #: 10234558301 — Completed: 04-27-2026
Well Constructor (Business Name): BUTTERFIELD INC	Lic. #: 7115 — Facility ID # (Public Wells):
Address: 14346 W ST RD 77 HAYWARD WI 54843-9790	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location

Town of SAND LAKE				Fire # (if avail.): 6870N
Street Address or Road Name and Number: VICTORY HEIGHTS CIRCLE				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.88232 °N -91.45607 °W				Method Code: GPS008
NW or Govt Lot #:	NW	Section: 11	Township: 39 N	Range: 9 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	124

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	1
		Y		Y-SAND & GRAVEL	1	6
G	A	Y		G-GRAY A-COARSE Y-SAND & GRAVEL	6	55
T	N	X	M	T-TAN/BROWN N-FINE X-SAND & CLAY M-SILTY	55	105
	A	Y		A-COARSE Y-SAND & GRAVEL	105	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NAS PVC SDR17 250PSI ASTM F480	Surface	118
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3	10 CONTINUOUS SLOT STAINLESS STEEL	118	124

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
TD-16 BENTONITE GROUT	Surface	115	8 S

9. Static Water Level

5 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAB	6349	04-27-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JSM	7418	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	100	Septic or Holding, or POWTS Tank	=	40

Comment:

Created On: 04-27-2026 Updated On: 10-15-2026 Review Status: APPROVED