

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM883		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WILIS				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 4403 RAVINE RIDGE DR						Village of RICHFIELD					
City RICHFIELD				State WI		Zip Code 53027					
County Washington		Co. Permit #		Notification # 10234032801		Completed 04-23-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) ROSCHI BROS WELL DRLG & PUMP INC				Lic. # 435		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.2156 °N -88.2589 °W		Method Code GPS008	
Address N10W28210 NORTHVIEW RD WAUKESHA WI 53188-9401				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 28 9 N 19 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		2. Well Type New Well of previous unique well # constructed in			
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ?					
						Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock			
6		Surface		197		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
C Z		C-CLAY Z-W/COBBLES/BOULDERS		Surface		43					
Y C		Y-SAND & GRAVEL C-CLAYEY		43		87					
K C		K-BLACK C-CLAY		87		104					
K X		K-BLACK X-SAND & CLAY		104		116					
X		X-SAND & CLAY		116		194					
Y		Y-SAND & GRAVEL		194		197					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)					
6		BLACK STEEL PIPE WELDED JOINTS 18.97LB ASTM A53 1780PSI NUCOR		Surface		197					
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)					
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface									
9. Static Water Level											
110 ft. below ground surface											
10. Pump Test											
Pumping level 140 ft. below surface Pumping at 20 GP M for 3.5 Hrs. Pumping Method ? Airlift											
11. Well Is											
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
TK		6203		04-23-2026							
Drill Rig Operator											
Lic or Reg #		Date Signed									
EK		8767		04-23-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 04-27-2026

Updated On: 05-26-2026

Review Status: APPROVED