Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM883

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WILIS			Phone #
Mailing Address: 4403 RAVINE RIDGE DR			
City: RICHFIELD	State: WI	Zip Code: 53027	
County: Washington	Co. Permit #:	Notification #: 10234032801	Completed: 04-23-2026

1. Well Location

Village of RICHFIELD

Fire # (if avail.)

Street Address or Road Name and Number: 4403 RVINE RIDGE DR

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROSCHI BROS WELL DRLG & PUMP INC	435	

Latitude / Longitude in Decimal Degree (DD): 43.2156 °N -88.2589 °W

Method Code: GPS008

Address: N10W28210 NORTHVIEW RD
WAUKESHA WI 53188-9401

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

SW	NW	Section	Township	Range
or Govt Lot #		28	9 N	19 E

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.7

Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	197

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	Z	C-CLAY Z-W/COBBLES/BOULDERS	Surface	43
		Y	C	Y-SAND & GRAVEL C-CLAYEY	43	87
K		C		K-BLACK C-CLAY	87	104
K		X		K-BLACK X-SAND & CLAY	104	116
		X		X-SAND & CLAY	116	194
		Y		Y-SAND & GRAVEL	194	197

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS 18.97LB ASTM A53 1780PSI NUCOR	Surface	197
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

110 ft. below ground surface

10. Pump Test

Pumping level 140 ft. below surface

Pumping at 20 GP M for 3.5 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TK	6203	04-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EK	8767	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 04-27-2026 Updated On: 05-26-2026 Review Status: APPROVED