Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM887

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MATTHEW RAMERTH	Phone #
Mailing Address: N3345 980 ST	
City: DIAMOND BLUFF	State: WI Zip Code: 54014
County: Pierce	Co. Permit #:
Notification #: 10023946501	Completed: 04-27-2026
Well Constructor (Business Name): HOYER BROTHERS WELL DRILLING INC	Lic. #: 60
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: W5077 250TH AVE BAY CITY WI 54723	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of DIAMOND BLUFF	Fire # (if avail.): N3345
Street Address or Road Name and Number: 980 ST	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.66074 °N -92.6251 °W	Method Code: SCR002

SW	SE	Section	Township	Range
or Govt Lot #		12	25 N	19 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: TIN CASING

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable | Borehole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	104
6	104	370

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 12depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT	Surface	104
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	104	32

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	C	C	T-TAN/BROWN M-MEDIUM C-CLAY C-CLAYEY	Surface	20
Y	H	L	L	Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	20	180
T	H	N	N	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	180	320
E	H	N	N	E-GREEN H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	320	350
G	H	N	N	G-GRAY H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	350	370

9. Static Water Level	11. Well Is
280 ft. below ground surface	12 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 280 ft. below surface	Disinfected ? Yes
Pumping at 12 GP M for 2 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH	7287	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TH	7287	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-27-2026 Updated On: 05-26-2026 Review Status: APPROVED

WISCONSIN UNIQUE WELL NUMBER **ACM887**