

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM887		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner MATTHEW RAMERTH						Phone #										
Mailing Address N3345 980 ST						1. Well Location						Fire # (if avail.)				
City DIAMOND BLUFF						State WI		Zip Code 54014				Town of DIAMOND BLUFF		N3345		
County Pierce						Co. Permit #		Notification # 10023946501				Completed 04-27-2026		Street Address or Road Name and Number 980 ST		
Well Constructor (Business Name) HOYER BROTHERS WELL DRILLING INC						Lic. # 60		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.66074 °N -92.6251 °W		Method Code SCR002		
Address W5077 250TH AVE BAY CITY WI 54723						Well Plan Approval #		SW SE		Section 12		Township 25 N		Range 19 W		
Heat Exchange ___ # of drillholes						Approval Date (mm-dd-yyyy)		or Govt Lot #		2. Well Type Replacement		of previous unique well # constructed in				
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ? TIN CASING						
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled								
Private, potable Borehole						Hicap Property ? No										
Heat Exchange ___ # of drillholes						Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method												8. Geology				
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
10 Surface 104			No Rotary - Mud Circulation No								T M C C		T-TAN/BROWN M-MEDIUM C-CLAY C-CLAYEY		Surface 20	
6 104 370			No Rotary - Air No								Y H L L		Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC		20 180	
			Yes Rotary - Air & Foam Yes								T H N N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE		180 320	
			No Drill-Through Casing Hammer								E H N N		E-GREEN H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE		320 350	
			No Reverse Rotary								G H N N		G-GRAY H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE		350 370	
			No Cable-tool Bit ___ in. dia... No													
			No Dual Rotary No													
			Yes Temp. Outer Casing 10in. dia													
			Yes Removed? 12depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT				Surface		104								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material																
Method TREMIE PIPE - PUMPED																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
CEMENT				Surface		104		32								

9. Static Water Level

280 ft. below ground surface

10. Pump Test

Pumping level 280 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Yes

Filled & Sealed Well(s) as needed?

Yes

13. Constructor / Supervisory Driller

Lic #

Date Signed

TH

7287

04-27-2026

Drill Rig Operator

Lic or Reg #

Date Signed

TH

7287

04-27-2026

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type

Qualifier

Distance

POWTS dispersal component (soil absorption unit or mound)

>

55

Comment:

Created On: 04-27-2026

Updated On: 05-26-2026

Review Status: APPROVED