

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM888		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HILDEBRANT MIKE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W9144 690 ST						Town of RIVER FALLS						W9144					
City RIVER FALLS						State WI		Zip Code 54022				Street Address or Road Name and Number 690 ST					
County Pierce		Co. Permit #		Notification # 10226601101		Completed 04-27-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) HOYER BROTHERS WELL DRILLING INC				Lic. # 60		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7932 °N -92.59135 °W		Method Code SCR002					
Address W5077 250TH AVE BAY CITY WI 54723				Well Plan Approval #		SE SW		Section 29		Township 27 N		Range 18 W					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? BAD WATER											
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled											
Private, potable		Borehole		Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		104		No Rotary - Mud Circulation		No		T S C C		T-TAN/BROWN S-SOFT/LOOSE C-CLAY C-CLAYEY		Surface		15	
6		104		230		No Rotary - Air		No		T A Z C		T-TAN/BROWN A-COARSE Z-CLAY & GRAVEL C-CLAYEY		15		36	
4		230		270		Yes Rotary - Air & Foam		Yes		U D C C		U-BLUE D-DECOMPOSED/WEATHERED C-CLAY C-CLAYEY		36		60	
						No Drill-Through Casing Hammer				K H P R		K-BLACK H-HARD/FIRM P-HARDPAN R-W/CHERT		60		90	
						No Reverse Rotary				G M N N		G-GRAY M-MEDIUM N-SANDSTONE N-W/SANDSTONE		90		230	
						No Cable-tool Bit ___ in. dia...		No		G H L L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC		230		270	
						No Dual Rotary		No									
						Yes Temp. Outer Casing 10in. dia											
						No Removed? 38depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT				Surface		104									
4		SDR 21, SCH 40 PVC WEST LAKE, GLUED				10		230									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material																	
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT GROUT		Surface		104		5050 S											

9. Static Water Level

180 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Yes

AWAITING COUNTY FINANCING

Filled & Sealed Well(s) as needed?

Yes

AWAITING COUNTY FINANCING

13. Constructor / Supervisory Driller

Lic #

Date Signed

TH

7287

04-27-2026

Drill Rig Operator

Lic or Reg #

Date Signed

TH

7287

04-27-2026

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type

Qualifier

Distance

POWTS dispersal component (soil absorption unit or mound)

>

55

Comment:

Created On: 04-27-2026

Updated On: 05-26-2026

Review Status: APPROVED