Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM888

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HILDEBRANT MIKE		Phone #
Mailing Address: W9144 690 ST		
City: RIVER FALLS	State: WI	Zip Code: 54022

County	Co. Permit #	Notification #	Completed
Pierce		10226601101	04-27-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HOYER BROTHERS WELL DRILLING INC	60	

Address: W5077 250TH AVE
BAY CITY WI 54723

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity

1. Well Location

Town of RIVER FALLS

Fire # (if avail.): W9144

Street Address or Road Name and Number: 690 ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.7932 °N -92.59135 °W

Method Code: SCR002

SE SW or Govt Lot #	Section	Township	Range
	29	27 N	18 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

BAD WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Borehole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	104
6	104	230
4	230	270

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
No	Removed? 38depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT	Surface	104
4	SDR 21, SCH 40 PVC WEST LAKE, GLUED	10	230
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	104	5050 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	C	C	T-TAN/BROWN S-SOFT/LOOSE C-CLAY C-CLAYEY	Surface	15
T	A	Z	C	T-TAN/BROWN A-COARSE Z-CLAY & GRAVEL C-CLAYEY	15	36
U	D	C	C	U-BLUE D-DECOMPOSED/WEATHERED C-CLAY C-CLAYEY	36	60
K	H	P	R	K-BLACK H-HARD/FIRM P-HARDPAN R-W/CHERT	60	90
G	M	N	N	G-GRAY M-MEDIUM N-SANDSTONE N-W/SANDSTONE	90	230
G	H	L	L	G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	230	270

9. Static Water Level

180 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

AWAITING COUNTY FINANCING

Filled & Sealed Well(s) as needed? Yes

AWAITING COUNTY FINANCING

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH	7287	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TH	7287	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-27-2026 Updated On: 05-26-2026 Review Status: APPROVED

WISCONSIN UNIQUE WELL NUMBER **ACM888**