

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM891		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WISNIEWSKI TOMASZ				Phone # (715)594-3769		1. Well Location				Fire # (if avail.)	
Mailing Address W4616 CTY RD G						Town of EL PASO				W4616	
City ELLSWORTH				State WI		Zip Code 54011				Street Address or Road Name and Number CTY RD G	
County Pierce		Co. Permit #		Notification # 10207946001		Completed 04-27-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HOYER BROTHERS WELL DRILLING INC				Lic. # 60		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.7618 °N -92.3647 °W		Method Code SCR002	
Address W5077 250TH AVE BAY CITY WI 54723				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 6 26 N 16 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity							
3. Well serves 1 # of HOME				Hicap Well ? No							
Private, potable Borehole				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
10 Surface 104			No Rotary - Mud Circulation No			T M C C			Type, Caving/Noncaving, Color, Hardness, etc... T-TAN/BROWN M-MEDIUM C-CLAY C-CLAYEY Surface 55		
6 104 230			No Rotary - Air No			T X L C			T-TAN/BROWN X-LENSED/STREAKED/LAYERED L-LIMESTONE/DOLOMITE C-CLAYEY 55 90		
			Yes Rotary - Air & Foam Yes			Y H L L			Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC 90 230		
			No Drill-Through Casing Hammer								
			No Reverse Rotary								
			No Cable-tool Bit ___ in. dia... No								
			No Dual Rotary No								
			Yes Temp. Outer Casing 10in. dia								
			Yes Removed? 12depth ft. (If NO explain on back side)								
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
6		STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT				Surface		104			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement				
CEMENT			Surface		104		30 S				
9. Static Water Level 160 ft. below ground surface											
10. Pump Test Pumping level 160 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
TH								7287		04-27-2026	
Drill Rig Operator								Lic or Reg #		Date Signed	
TH								7287		04-27-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-27-2026

Updated On: 05-26-2026

Review Status: APPROVED