Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM891

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WISNIOWSKI TOMASZ	Phone #: (715)594-3769
Mailing Address: W4616 CTY RD G	
City: ELLSWORTH	State: WI Zip Code: 54011
County: Pierce	Co. Permit #:
Notification #: 10207946001	Completed: 04-27-2026
Well Constructor (Business Name): HOYER BROTHERS WELL DRILLING INC	Lic. #: 60
Facility ID # (Public Wells):	
Address: W5077 250TH AVE BAY CITY WI 54723	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of EL PASO	Fire # (if avail.): W4616
Street Address or Road Name and Number: CTY RD G	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.7618 °N -92.3647 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 6 Township: 26 N Range: 16 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Borehole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	104
6	104	230

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 12depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	C	C	T-TAN/BROWN M-MEDIUM C-CLAY C-CLAYEY	Surface	55
T	X	L	C	T-TAN/BROWN X-LENSED/STREAKED/LAYERED L-LIMESTONE/DOLOMITE C-CLAYEY	55	90
Y	H	L	L	Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	90	230

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL,18.97,A53,SCH40,IPCSO,WELDED JOINT	Surface	104
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

160 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	104	30 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH	7287	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TH	7287	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-27-2026 Updated On: 05-26-2026 Review Status: APPROVED