Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM895

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAREK, TODD	Phone #
Mailing Address: 918 CTY RD T	
City: HAMMOND	State: WI — Zip Code: 54015
County: St. Croix	Co. Permit #: — Notification #: 10198186101 — Completed: 04-27-2026
Well Constructor (Business Name): HOYER BROTHERS WELL DRILLING INC	Lic. #: 60 — Facility ID # (Public Wells):
Address: W5077 250TH AVE, BAY CITY WI 54723	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of HAMMOND	Fire # (if avail.): 918
Street Address or Road Name and Number: CTY RD T	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9957 °N -92.4368 °W	Method Code: SCR002
SE SE or Govt Lot #: — Section: 16 — Township: 29 N — Range: 17 W	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable — Borehole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	145
6	145	187

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	Y	C	T-TAN/BROWN S-SOFT/LOOSE Y-SAND & GRAVEL C-CLAYEY	Surface	62
T	S	N	N	T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE N-W/SANDSTONE	62	100
T	M	L	L	T-TAN/BROWN M-MEDIUM L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	100	187

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 19.45,A53B,SHC40,IPSCO, T&C	Surface	62
4	STEEL,11.00, A53 SCH 40 IPSCO	40	145
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	62	2

9. Static Water Level
90 ft. below ground surface

10. Pump Test
Pumping level 90 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH	7287	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TH	7287	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-27-2026 Updated On: 05-26-2026 Review Status: APPROVED