

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM900		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MEEKS, DENNIS & KAELEEN						Phone #																	
Mailing Address S2425 CTY HWY V						Town of FOREST																	
City HILLSBORO						State WI		Zip Code 54634															
County Vernon		Co. Permit #		Notification # 9406943101		Completed 04-23-2026		1. Well Location															
Well Constructor (Business Name) KOUBA DRILLING LLC						Lic. # 8148		Facility ID # (Public Wells)															
Address 325 S PARK ST REEDSBURG WI 53959						Well Plan Approval #		Latitude / Longitude in Decimal Degree (DD) 43.64172 °N -90.45287 °W															
Hicap Permanent Well #						Common Well #		Specific Capacity 0.1															
3. Well serves 1 # of HOME & BARN Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Method Code SCR002 SE SE Section Township Range or Govt Lot # 35 14 N 1 W															
4. Potential Contamination Sources - ON REVERSE SIDE						2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																	
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock									Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)							
10 Surface 188.5			No Rotary - Mud Circulation No									C		C-CLAY		Surface 8							
6 188.5 305			No Rotary - Air No Yes Rotary - Air & Foam Yes No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									H L		H-HARD/FIRM L-LIMESTONE/DOLOMITE		8 37							
												C L		C-CAVERNOUS L-LIMESTONE/DOLOMITE		37 39							
												H L		H-HARD/FIRM L-LIMESTONE/DOLOMITE		39 80							
												M N		M-MEDIUM N-SANDSTONE		80 125							
												M H		M-MEDIUM H-SHALE		125 172							
												H H		H-HARD/FIRM H-SHALE		172 245							
												H N		H-HARD/FIRM N-SANDSTONE		245 305							
6. Casing, Liner, Screen																							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)													
6		WHEATLAND STEEL, WELDED, .280 WALL, ASTM A53B, DRIVE SHOE						Surface		188.5													
Dia. (in.)		Screen type, material & slot size						From (ft.)		To (ft.)													
7. Grout or Other Sealing Material																							
Method TREMIE PIPE - PUMPED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
NEAT CEMENT GROUT				Surface		188.5		69 S															

9. Static Water Level

204 ft. below ground surface

10. Pump Test

Pumping level 285 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

MLK

8149

04-27-2026

Drill Rig Operator

Lic or Reg #

Date Signed

BW

8946

04-23-2026

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

CREW ENCOUNTERED VOID IN LIMESTONE AT 37 TO 39 FT THAT REQUIRED 6 BAGS OF 3/8" HYDRATED CHIPS TO SEAL OFF IN ORDER TO CONTINUE TO CEMENT GROUT TO SURFACE.

Created On: 04-27-2026

Updated On: 05-28-2026

Review Status: APPROVED