Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM902

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LENIUS,NATHAN			Phone #
Mailing Address: 7317 CR C			
City: STURGEON BAY	State: WI	Zip Code: 54235	
County: Door	Co. Permit #:	Notification #: 10120521701	Completed: 04-16-2026
Well Constructor (Business Name): GROUND SOURCE LLC	Lic. #: 9443	Facility ID # (Public Wells):	
Address: 3671 MONROE ROAD DEPERE WI 54115		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of NASEWAUPEE				Fire # (if avail.): 7317
Street Address or Road Name and Number: CR C				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.8347 °N -87.4585 °W				Method Code: GPS008
NE NE or Govt Lot #	Section: 9	Township: 27 N	Range: 25 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
8	6	174
6	174	220

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 6depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	G-GRAVEL/STONES	Surface	6
L	L-LIMESTONE/DOLOMITE	6	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLN END BLK STEEL WELDED 18.97.280 A53 NUCOR	Surface	174
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	174	30 S

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TS	6667	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CV		04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		60	POWTS dispersal component (soil absorption unit or mound)		80

Comment:

Created On: 04-27-2026 Updated On: 10-15-2026 Review Status: APPROVED