

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM902		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A												
Property Owner LENIUS,NATHAN						Phone #		1. Well Location				Fire # (if avail.)										
Mailing Address 7317 CR C						Town of NASEWAUPEE						7317										
City STURGEON BAY						State WI		Zip Code 54235				Street Address or Road Name and Number										
County						Co. Permit #		Notification #				Completed										
Door						10120521701		04-16-2026				Subdivision Name										
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)										
GROUND SOURCE LLC						9443		44.8347 °N -87.4585 °W				Method Code										
Address 3671 MONROE ROAD DEPERE WI 54115						Well Plan Approval #		NE NE		Section 9		Township 27 N										
Heat Exchange ___ # of drillholes						Approval Date (mm-dd-yyyy)		or Govt Lot #		Range 25 E		2. Well Type New Well										
Hicap Permanent Well #						Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?										
3. Well serves 1 # of HOME						Hicap Well ? No		Hicap Property ? No				Construction Type Drilled										
Private,potable						Hicap Potable ? No																
4. Potential Contamination Sources - ON REVERSE SIDE																						
5. Drillhole Dimensions and Construction Method														8. Geology								
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10			Surface			6			No Rotary - Mud Circulation			No			G		G-GRAVEL/STONES		Surface		6	
8			6			174			Yes Rotary - Air			Yes			L		L-LIMESTONE/DOLOMITE		6		220	
6			174			220			No Rotary - Air & Foam			No										
									No Drill-Through Casing Hammer													
									No Reverse Rotary													
									No Cable-tool Bit ___ in. dia...			No										
									No Dual Rotary			No										
									Yes Temp. Outer Casing 8in. dia													
									Yes Removed? 6depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is				
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)		To (ft.)		60 ft. below ground surface				12 in. above grade					
6			NEW PLN END BLK STEEL WELDED 18.97.280 A53 NUCOR						Surface		174		10. Pump Test				Developed ? Yes					
Dia. (in.)			Screen type, material & slot size						From (ft.)		To (ft.)		Pumping level 120 ft. below surface				Disinfected ? Yes					
													Pumping at 30 GP M for 1 Hrs.				Capped ? Yes					
													Pumping Method ? Airlift									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No								
Method BRADENHEAD																						
Kind of Sealing Material						From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed? No								
NEAT CEMENT GROUT						Surface		174		30 S												
														13. Constructor / Supervisory Driller				Lic #		Date Signed		
														TS				6667		04-27-2026		
														Drill Rig Operator				Lic or Reg #		Date Signed		
														CV						04-27-2026		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	POWTS holding component (also known as holding tank)		60

Comment:

Created On: 04-27-2026

Updated On: 05-26-2026

Review Status: APPROVED