Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM905

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SKODA, ADAM	Phone #
Mailing Address: 210 4TH. STREET E.	
City: CRESCO	State: IA — Zip Code: 52136
County: Burnett	Co. Permit #: — Notification #: 10233654504 — Completed: 04-24-2026
Well Constructor (Business Name): JEREMY BEECROFT WELL DRILLING	Lic. #: 6457 — Facility ID # (Public Wells):
Address: W7414 MILLER RD, SPOONER WI 54801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of SWISS				Fire # (if avail.): 29659
Street Address or Road Name and Number: 29659 LONG LAKE TRAIL				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 45.9854 °N -92.3629 °W				Method Code: GPS008
SE SE or Govt Lot #	Section: 33	Township: 41 N	Range: 16 W	

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: SLOW POINT

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	143

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	15
		Y	C	Y-SAND & GRAVEL C-CLAYEY	15	50
		S	M	S-SAND M-SILTY	50	130
		S		S-SAND	130	143

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	SDR17 PVC CASING WELDED ASTM F480	Surface	138
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	15 SLOT SS SCREEN	138	143

7. Grout or Other Sealing Material

Method TREMIE PIPE- PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	133	12 S

9. Static Water Level

36 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 40 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JB	6457	04-27-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF	8979	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100	POWTS dispersal component (soil absorption unit or mound)		110

Comment:

Created On: 04-27-2026 Updated On: 10-15-2026 Review Status: APPROVED