

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM913		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SPINDLER, LES					Phone # (920)428-3551			1. Well Location			Fire # (if avail.)		
Mailing Address 149 SUNNY MEADOW DR								Town of TOWNSEND			18631		
City KAUKAUNA					State WI		Zip Code 54130					Street Address or Road Name and Number ELDORADO RD	
County Oconto		Co. Permit #		Notification # 10206043301		Completed 04-27-2026		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) DRILL BABY DRILL LLC				Lic. # 9442		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.358 °N -88.6051 °W			Method Code SCR002		
Address DBA LUISIER WELL DRILLING INC 220 HANK MARKS DR OCONTO FALLS WI 54154				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 10 33 N 15 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? SANDPOINT					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0				Construction Type Drilled					
3. Well serves 1 # of HOME				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
8.75		Surface		75		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T X T-TAN/BROWN X-SAND & CLAY Surface 15 Y Z Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS 15 75			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
5		NASP PVC-SS120 SCH 40 200 PSI F-480				Surface		71		27 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test			
5		18 SLOT S.S. SCREEN				71		75		Pumping level 65 ft. below surface Pumping at 30 GP M for 1 Hrs. Pumping Method ? Airlift			
7. Grout or Other Sealing Material													
Method TREMIE PIPE - GRAVITY													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is					
QUIK GROUT		Surface		71		8 S		24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
#40 GRAVEL PACK (RED FLINT SAND & GRAVEL LLC)		71		75		6 S		12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
KM		5864		04-27-2026									
Drill Rig Operator		Lic or Reg #		Date Signed									
ZJ`		8833											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	92	Septic or Holding, or POWTS Tank	=	41

Comment: WE WILL BE INSTALLING THE WATER SYSTEM.**Created On:** 04-27-2026**Updated On:** 05-19-2026**Review Status:** APPROVED