Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM916

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VICK RYAN	Phone #
Mailing Address: N5996 CTH C	
City: WEST SALEM	State: WI — Zip Code: 54669
County: La Crosse	Co. Permit #: 2025037 — Notification #: 10232468601 — Completed: 04-27-2026
Well Constructor (Business Name): LYSAKER, TIMOTHY M	Lic. #: 6199 — Facility ID # (Public Wells)
Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC N7912 BLUFFVIEW CT HOLMEN WI 54636	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.6

1. Well Location

Town of HAMILTON	Fire # (if avail.): N5996
Street Address or Road Name and Number: N5996 CTH C	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 43.9386 °N -91.07396 °W	Method Code: SCR002
SE NE or Govt Lot #:	Section: 22 — Township: 17 N — Range: 6 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	48

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	15
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	15	38
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	38	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK P.E. STEEL .280 WALL 18.97 # ASTM A53 B WHEATLAND	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.5	CONTINUOUS 12 SLOT STAINLESS STEEL	44	48

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	44	3 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL	6199	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TL	9201	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		32	POWTS dispersal component (soil absorption unit or mound)		63
			Building Drain - Sanitary		26

Comment:

Created On: 04-28-2026 Updated On: 10-15-2026 Review Status: APPROVED