

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM916		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner VICK RYAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N5996 CTH C						Town of HAMILTON						N5996							
City WEST SALEM						State WI		Zip Code 54669				Street Address or Road Name and Number N5996 CTH C							
County La Crosse		Co. Permit # 2025037		Notification # 10232468601		Completed 04-27-2026		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) LYSAKER, TIMOTHY M				Lic. # 6199		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9386 °N -91.07396 °W				Method Code SCR002					
Address TIM LYSAKER WELL DRLG & PUMP SERV LLC N7912 BLUFFVIEW CT HOLMEN WI 54636				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 22 17 N 6 W		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		48		No Rotary - Mud Circulation		No		T Q X		T-TAN/BROWN Q-CAVING X-SAND & CLAY		Surface		15			
						No Rotary - Air		No		T Q S		T-TAN/BROWN Q-CAVING S-SAND		15		38			
						No Rotary - Air & Foam		No		T Q Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL		38		48			
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						Yes Cable-tool Bit 6in. dia...		No											
						No Dual Rotary		No											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				16 in. above grade					
6		NEW BLACK P.E. STEEL .280 WALL 18.97 # ASTM A53 B WHEATLAND				Surface		44		10. Pump Test Pumping level 35 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
5.5		CONTINUOUS 12 SLOT STAINLESS STEEL				44		48											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method												Filled & Sealed Well(s) as needed? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
GRANULAR BENTONITE				Surface		44		3 S		TL				6199		04-27-2026			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										TL				9201		04-27-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		32	POWTS dispersal component (soil absorption unit or mound)		63
			Building Drain - Sanitary		26

Comment:

Created On: 04-28-2026

Updated On: 05-28-2026

Review Status: APPROVED