Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM922

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUNICK, CRAIG	Phone #: (920)676-0437
Mailing Address: 2643 US 45	
City: EAGLE RIVER	State: WI Zip Code: 54521
County: Vilas	Co. Permit #:
Notification #: 10232506601	Completed: 04-27-2026
Well Constructor (Business Name): RHINELANDER WELL DRILLING INC	Lic. #: 632
Facility ID # (Public Wells):	
Address: PO BOX 584 3790 COUNTRY DR RHINELANDER WI 54501-0584	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of LINCOLN	Fire # (if avail.): 2643
Street Address or Road Name and Number: US 45	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9781 °N -89.2486 °W	Method Code: GPS008

NW	SE	Section	Township	Range
or Govt Lot #		4	40 N	10 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	76

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	15
G		Y		G-GRAY Y-SAND & GRAVEL	15	40
G		C		G-GRAY C-CLAY	40	66
T		Y		T-TAN/BROWN Y-SAND & GRAVEL	66	76

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 GRADE B PLAINEND WELDED WHEATLAND TUBE 19 LBS PER FT	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL ALLOY 15 SLOT	73	76

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DGF	8303	04-28-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JCE	9286	04-28-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Septic or Holding, or POWTS Tank		85

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	04/28/2026	NEW BUILD

Created On: 04-28-2026 Updated On: 05-28-2026 Review Status: APPROVED