

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM930		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ELLIS INDUSTRIES INC						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 330						Town of WASHINGTON							
City BANCROFT						State WI		Zip Code 54921					
County Vilas		Co. Permit #		Notification #		Completed 12-30-2025		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ROBERTS IRRIGATION CO INC				Lic. # 3262		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.9733 °N -89.2283 °W				Method Code GPS008	
Address 1500 POST RD PLOVER WI 54467				Well Plan Approval # 96138		Approval Date (mm-dd-yyyy) 04-22-2026		SW SE Section Township Range or Govt Lot # 3 40 N 10 E		2. Well Type Replacement			
Hicap Permanent Well # 96138		Common Well #		Specific Capacity 87.5		Reason for replaced or reconstructed well ? WELL FAILURE/PUMPING SAND							
3. Well serves 1 # of CENTER PIVOT Private, non-potable Heat Exchange ___ # of drillholes				Hicap Well ? Yes Hicap Property ? Yes Hicap Potable ? No		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
30		Surface		79		No Rotary - Mud Circulation		No		Geology Codes			
						No Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc...			
						No Rotary - Air & Foam		No		K I K S K-BLACK I-SOIL-ORGANIC			
						No Drill-Through Casing Hammer		No		From (ft.) To (ft.)			
						No Reverse Rotary		No		Surface 2			
						No Cable-tool Bit ___ in. dia...		No		2 79			
						Yes Dual Rotary		No		T-TAN/BROWN K-COBBLERS/BOULDERS S-SANDY			
						No Temp. Outer Casing ___ in. dia		No					
						No Removed? ___ depth ft. (If NO explain on back side)		No					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
16		ASTM A53B STEEL WELDED #62.5 PRFT				Surface		49		22 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
16		.110 ROSCOE MOSS V-WIRE				49		79		14 in. above grade			
7. Grout or Other Sealing Material													
Method													
12. Notified Owner of need to fill & seal ? YES										Yes			
Filled & Sealed Well(s) as needed? NO PUMP IN WELL										Yes			
13. Constructor / Supervisory Driller								Lic #		Date Signed			
RIC								8923		04-28-2026			
Drill Rig Operator								Lic or Reg #		Date Signed			
JG								8923		04-28-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

PREVIOUS WELL DRILLER DID NOT FILL OUT THE PROPER PAPERWORK REQUIRED.

Abandonment Type	Abandonment Date	Procedure	Reason
	05/28/2026	5 YARDS OF CONCRETE	REPLACED BY ACM592, WELL FAILURE, PUMPING SAND

Created On: 04-28-2026

Updated On: 06-04-2026

Review Status: APPROVED