Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM930

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ELLIS INDUSTRIES INC	Phone #
Mailing Address: PO BOX 330	
City: BANCROFT	State: WI Zip Code: 54921
County: Vilas	Co. Permit #	Notification #	Completed: 12-30-2025

1. Well Location

Town of WASHINGTON

Fire # (if avail.)

Street Address or Road Name and Number: EAST OF DEERVIEW LN, NORTH OF HWY 17

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROBERTS IRRIGATION CO INC	3262	

Address: 1500 POST RD, PLOVER WI 54467

Well Plan Approval #: 96138

Approval Date (mm-dd-yyyy): 04-22-2026

Hicap Permanent Well #	Common Well #	Specific Capacity
96138		87.5

Latitude / Longitude in Decimal Degree (DD): 45.9733 °N -89.2283 °W

Method Code: GPS008

SW	SE	Section	Township	Range
or Govt Lot #		3	40 N	10 E

2. Well Type Replacement

of previous unique well # ABZ953 constructed in 2024

Reason for replaced or reconstructed well ?: WELL FAILURE/PUMPING SAND

Construction Type: Drilled

3. Well serves 1 # of CENTER PIVOT

Private, non-potable

Heat Exchange____# of drillholes

Hicap Well ? Yes

Hicap Property ? Yes

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
30	Surface	79

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		K-BLACK I-SOIL-ORGANIC	Surface	2
T		K	S	T-TAN/BROWN K-COBBLES/BOULDERS S-SANDY	2	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
16	ASTM A53B STEEL WELDED #62.5 PRFT	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
16	.110 ROSCOE MOSS V-WIRE	49	79

7. Grout or Other Sealing Material

Method

9. Static Water Level

22 ft. below ground surface

10. Pump Test

Pumping level 24 ft. below surface

Pumping at 175 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

YES

Filled & Sealed Well(s) as needed? Yes

NO PUMP IN WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
RICI		04-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JG	8923	04-28-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: PREVIOUS WELL DRILLER DID NOT FILL OUT THE PROPER PAPERWORK REQUIRED.

Abandonment Type	Abandonment Date	Procedure	Reason
	05/28/2026	5 YARDS OF CONCRETE	REPLACED BY ACM592, WELL FAILURE, PUMPING SAND

Created On: 04-28-2026 Updated On: 06-04-2026 Review Status: APPROVED