Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM931

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MURPHY PAT	Phone #: (715)299-4578
Mailing Address: 214 N ROOSEVELT ROAD	
City: BLACK RIVER FALLS	State: WI — Zip Code: 54615

County	Co. Permit #	Notification #	Completed
Jackson	26111-1	10237984501	04-28-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
H2O WELL DRILLING & PUMP SERVICE LLC	7026	

Address: N5858 STATE HIGHWAY 54
BLACK RIVIER FALLS WI 54615

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

3. Well serves 1 # of MOBILE HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of CURRAN

Fire # (if avail.): N7311

Street Address or Road Name and Number: DAVIS ROAD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.3357 °N	-91.0852 °W			SCR002

SE	SE	Section	Township	Range
or Govt Lot #		34	22 N	6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	I		K-BLACK S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	1
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	1	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS WIRE WRAPPED .010 SLOT	36	40

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	36	2 S

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GR	7138	04-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	=	47	POWTS dispersal component (soil absorption unit or mound)	>	55

Comment:

Created On: 04-28-2026 Updated On: 05-28-2026 Review Status: APPROVED