Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM932

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUJAWA MIKE & JESSICA	Phone #: (630)418-5457
Mailing Address: 8332 MENDING WALL DRIVE	
City: WOODRIDGE	State: IL — Zip Code: 60517
County: Juneau	Co. Permit #: — Notification #: 10235275501 — Completed: 04-24-2026
Well Constructor (Business Name): H2O WELL DRILLING & PUMP SERVICE LLC	Lic. #: 7026 — Facility ID # (Public Wells):
Address: N5858 STATE HIGHWAY 54, BLACK RIVIER FALLS WI 54615	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well # — Specific Capacity: 1.7

1. Well Location

Town of NECEDAH	Fire # (if avail.): N9560
Street Address or Road Name and Number: 18TH AVE	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 43.99073 °N -90.02444 °W	Method Code: SCR002
SW NE or Govt Lot #	Section: 33 — Township: 18 N — Range: 4 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	35
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	35	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS WIRE WRAPPED .010	36	40

9. Static Water Level

11 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	36	2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GR	7138	04-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	60	POWTS dispersal component (soil absorption unit or mound)	>	75

Comment:

Created On: 04-28-2026 Updated On: 05-28-2026 Review Status: APPROVED