Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM934

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ADAMS REID	Phone #
Mailing Address: W300S10397 LAKE SIDE DRIVE	
City: MUKWONAGO	State: WI — Zip Code: 53149
County: Monroe	Co. Permit #: — Notification #: 10238898601 — Completed: 04-24-2026
Well Constructor (Business Name): H2O WELL DRILLING & PUMP SERVICE LLC	Lic. #: 7026 — Facility ID # (Public Wells):
Address: N5858 STATE HIGHWAY 54, BLACK RIVIER FALLS WI 54615	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of SCOTT	Fire # (if avail.): 2587
Street Address or Road Name and Number: CRESCENT ROAD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1331 °N -90.3331 °W	Method Code: SCR002
NE SE or Govt Lot #:	Section: 11 — Township: 19 N — Range: 1 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	38
T	B	N		T-TAN/BROWN B-BROKEN N-SANDSTONE	38	46
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	46	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

9 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	46	4 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GR	7138	04-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-28-2026 Updated On: 05-28-2026 Review Status: APPROVED