

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM934		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner ADAMS REID					Phone #		1. Well Location Fire # (if avail.) 2587					
Mailing Address W300S10397 LAKE SIDE DRIVE												
City MUKWONAGO			State WI		Zip Code 53149		Town of SCOTT Street Address or Road Name and Number CRESCENT ROAD					
County Monroe		Co. Permit #		Notification # 10238898601		Completed 04-24-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) H2O WELL DRILLING & PUMP SERVICE LLC				Lic. # 7026		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.1331 °N -90.3331 °W			Method Code SCR002	
Address N5858 STATE HIGHWAY 54 BLACK RIVIER FALLS WI 54615				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 11 19 N 1 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0.4							
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
6		Surface		65		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				T Q X T-TAN/BROWN Q-CAVING X-SAND & CLAY Surface 38 T B N T-TAN/BROWN B-BROKEN N-SANDSTONE 38 46 I H N I-WHITE H-HARD/FIRM N-SANDSTONE 46 65		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 9 ft. below ground surface		
6		WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT				Surface		46		10. Pump Test Pumping level 40 ft. below surface Pumping at 12 GP M for 2 Hrs. Pumping Method ? Test Pump		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No			
GRANULAR BENTONITE			Surface		46		4 S					
13. Constructor / Supervisory Driller Lic # Date Signed GR 7138 04-28-2026 Drill Rig Operator Lic or Reg # Date Signed												

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-28-2026

Updated On: 05-28-2026

Review Status: APPROVED