Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM935

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FEISEL BRYAN	Phone #
Mailing Address: 1225 ROLLING HILLS TRAIL	
City: HUDSON	State: WI — Zip Code: 54016
County: Buffalo	Co. Permit #: — Notification #: 10203070201 — Completed: 04-22-2026
Well Constructor (Business Name): H2O WELL DRILLING & PUMP SERVICE LLC	Lic. #: 7026 — Facility ID # (Public Wells):
Address: N5858 STATE HIGHWAY 54 BLACK RIVIER FALLS WI 54615	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of ALMA	Fire # (if avail.): S2039
Street Address or Road Name and Number: GRANDVIEW DRIVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.3 °N -91.8992 °W	Method Code: SCR002
SW NE or Govt Lot #:	Section: 13 — Township: 21 N — Range: 13 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	400
6	400	700

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
No	Removed? 24depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT	Surface	400
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	400	220 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	Q	C	L	R-RED Q-CAVING C-CLAY L-LIMEY OR DOLOMITIC	Surface	18
Y	B	L	C	Y-YELLOW B-BROKEN L-LIMESTONE/DOLOMITE C-CLAYEY	18	24
T	F	L		T-TAN/BROWN F-FRACTURED L-LIMESTONE/DOLOMITE	24	320
G	M	H		G-GRAY M-MEDIUM H-SHALE	320	380
G	H	H		G-GRAY H-HARD/FIRM H-SHALE	380	500
T	H	N	H	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE H-SHALEY	500	700

9. Static Water Level	11. Well Is	
580 ft. below ground surface	24 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 660 ft. below surface	Disinfected ?	Yes
Pumping at 12 GP M for 2 Hrs.	Capped ?	Yes
Pumping Method ? Airlift		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GR	7138	04-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	60	POWTS dispersal component (soil absorption unit or mound)	>	75

Comment: LOST CIRCULATION AT 74'. TOOK 60 BAGS OF BENTONITE TO FILL IN VOID. BEFORE CEMENT CAME TO SURFACE.

Created On: 04-28-2026 Updated On: 10-15-2026 Review Status: APPROVED