

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM935		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FEISEL BRYAN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1225 ROLLING HILLS TRAIL								Town of ALMA				S2039			
City HUDSON						State WI		Zip Code 54016				Street Address or Road Name and Number GRANDVIEW DRIVE			
County Buffalo		Co. Permit #		Notification # 10203070201		Completed 04-22-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) H2O WELL DRILLING & PUMP SERVICE LLC				Lic. # 7026		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3 °N -91.8992 °W				Method Code SCR002	
Address N5858 STATE HIGHWAY 54 BLACK RIVIER FALLS WI 54615				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 13 21 N 13 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1											
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method												8. Geology			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)				
10 Surface 400			No Rotary - Mud Circulation No				R Q C L R-RED Q-CAVING C-CLAY L-LIMEY OR DOLOMITIC				Surface 18				
6 400 700			No Rotary - Air No				Y B L C Y-YELLOW B-BROKEN L-LIMESTONE/DOLOMITE C-CLAYEY				18 24				
			Yes Rotary - Air & Foam Yes				T F L T-TAN/BROWN F-FRACTURED L-LIMESTONE/DOLOMITE				24 320				
			No Drill-Through Casing Hammer				G M H G-GRAY M-MEDIUM H-SHALE				320 380				
			No Reverse Rotary				G H H G-GRAY H-HARD/FIRM H-SHALE				380 500				
			No Cable-tool Bit ___ in. dia... No				T H N H T-TAN/BROWN H-HARD/FIRM N-SANDSTONE H-SHALEY				500 700				
			No Dual Rotary No												
			Yes Temp. Outer Casing 10in. dia												
			No Removed? 24depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND ASTM 53B .280 WALL P/E 18.97#/FT				Surface		400							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		400		220 S							

9. Static Water Level

580 ft. below ground surface

10. Pump Test

Pumping level 660 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

GR

7138

04-28-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	60

Comment: LOST CIRCULATION AT 74'. TOOK 60 BAGS OF BENTONITE TO FILL IN VOID. BEFORE CEMENT CAME TO SURFACE.**Created On:** 04-28-2026**Updated On:** 05-28-2026**Review Status:** APPROVED