

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM938		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner TPD INCOME TRUST						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 731						Town of EAU PLEINE						4466							
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number 4466 BROCKHAUSE LN							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Portage				10232483801		04-23-2026													
Well Constructor (Business Name) DJ'S WATER SERVICE				Lic. # 7072		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6752 °N -89.6812 °W				Method Code GPS008					
Address 6522 OAK DR AMHERST WI 54406				Well Plan Approval #				NE SW		Section 4		Township 25 N		Range 7 E					
				Approval Date (mm-dd-yyyy)				or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity 8.5				2. Well Type Replacement				of previous unique well #		constructed in			
										Reason for replaced or reconstructed well ? NEW CONSTRUCTION									
3. Well serves 1 # of HOME				Hicap Well ? No						Construction Type Drilled									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		30								T Q Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL		Surface		30	
						No Rotary - Mud Circulation				No									
						No Rotary - Air				No									
						No Rotary - Air & Foam				No									
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		5 ft. below ground surface				21 in. above grade					
6		STEEL A53B 18.97 WHEATLAND WELD				Surface		26		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 7 ft. below surface				Disinfected ? Yes					
6		12 SLOT STAINLESS STEEL TELESCOPING				26		30		Pumping at 17 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				Yes			
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
GRANULAR BENTONITE				Surface		26		1 S											
13. Constructor / Supervisory Driller								Lic #		Date Signed									
DJFJ								6760		04-23-2026									
Drill Rig Operator								Lic or Reg #		Date Signed									
LM								7416		04-23-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	25	POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	25
			POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	04/23/2026	WILL COLLECT WATER SAMPLE ONCE THERE IS POWER

Created On: 04-28-2026

Updated On: 05-13-2026

Review Status: APPROVED