

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM941		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HARRIS EXTERIORS LLC						Phone # (608)604-6638		1. Well Location				Fire # (if avail.)			
Mailing Address 323 S WISCONSIN AVE						Village of MUSCODA						316			
City MUSCODA						State WI		Zip Code 53573				Street Address or Road Name and Number DEER RUN ROAD			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Grant				10246938003		04-28-2026									
Well Constructor (Business Name) FAHERTY, JEFFERY A				Lic. # 6819		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.1945 °N -90.4466 °W				Method Code SCR002	
Address PO BOX 247 PLATTEVILLE WI 53818				Well Plan Approval #		NW SW		Section 1		Township 8 N		Range 1 W		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well					
										of previous unique well # constructed in					
										Reason for replaced or reconstructed well ?					
3. Well serves 1 # of CABIN				Hicap Well ? No						Construction Type Drilled					
Private,potable				Drillhole		Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		66											
						<u>No</u> Rotary - Mud Circulation				<u>No</u>					
						<u>No</u> Rotary - Air				<u>No</u>					
						<u>No</u> Rotary - Air & Foam				<u>No</u>					
						<u>Yes</u> Drill-Through Casing Hammer									
						<u>No</u> Reverse Rotary									
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>					
						<u>No</u> Dual Rotary				<u>No</u>					
						<u>No</u> Temp. Outer Casing ___ in. dia									
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
S		S-SAND						Surface		66					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
4		WHEATLAND A53 STEEL 4"X21' T/C				Surface		63		9 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
4		T/C JOHNSON STAINLESS 10 SLOT				63		66		24 in. above grade					
7. Grout or Other Sealing Material										10. Pump Test					
Method MOUNDED										Pumping level 45 ft. below surface					
Kind of Sealing Material										Pumping at 18 GP M for 1 Hrs.					
GRANULAR BENTONITE										Pumping Method ? Airlift					
From (ft.) To (ft.) # Sacks Cement										Filled & Sealed Well(s) as needed?					
Surface										No					
										13. Constructor / Supervisory Driller					
										Lic #		Date Signed			
										JF		6819			
										Drill Rig Operator		Lic or Reg #			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 04-28-2026

Updated On: 05-29-2026

Review Status: APPROVED