

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM943		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner JK BUILDERS					Phone #		1. Well Location Fire # (if avail.) 89 Town of BLACK BROOK Street Address or Road Name and Number 75TH ST					
Mailing Address 160 8TH AVE												
City CLEAR LAKE			State WI	Zip Code 54005								
County Polk	Co. Permit #	Notification # 10248027801		Completed 04-30-2026		Subdivision Name			Lot # 2	Block #		
Well Constructor (Business Name) TIM BUTTERFIELD DRILLING INC			Lic. # 6900	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.22189 °N -92.3153 °W			Method Code SCR002			
Address 395 REED ST SOMERSET WI 54025			Well Plan Approval #		NE NW	Section 35	Township 32 N	Range 16 W				
			Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock					
6	Surface	205	No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary Yes No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
C		C-CLAY				Surface		140				
S N		S-SOFT/LOOSE N-SANDSTONE				140		180				
L		L-LIMESTONE/DOLOMITE				180		205				
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)							
6	NEW P&E BLK WELDED 18.97 LB/FT ASTM A53 NUCOR			Surface	180							
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)							
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement								
GRANULAR BENTONITE		Surface	20	2 S								
9. Static Water Level												
80 ft. below ground surface												
10. Pump Test												
Pumping level 120 ft. below surface												
Pumping at 10 GP M for 1 Hrs.												
Pumping Method ? Airlift												
11. Well Is												
18 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ?												
No												
Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller												
Lic #		Date Signed										
TB		6901		04-30-2026								
Drill Rig Operator		Lic or Reg #		Date Signed								
BK		9317		04-30-2026								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 04-29-2026

Updated On: 05-29-2026

Review Status: APPROVED