Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM944

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROCKETMAN INVESTMENTS	Phone #
Mailing Address: 4437 HWY 60	
City: SLINGER	State: WI Zip Code: 53086
County: Waukesha	Co. Permit #:
Notification #: 10128287901	Completed: 04-24-2026

1. Well Location

Village of LISBON

Fire # (if avail.)

Street Address or Road Name and Number: W257 N5916 AUTUMN WAY

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): SWEENEY, KENNETH R	Lic. #: 583
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: KEN SWEENEY WELL DRILLING & PUMPS 11221 W ST MARTINS RD FRANKLIN WI 53132-2331	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.7	

Latitude / Longitude in Decimal Degree (DD): 43.1254 °N -88.2597 °W
Method Code: GPS008

NW SW or Govt Lot # | Section: 28 | Township: 8 N | Range: 19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	241

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	Z	X-SAND & CLAY Z-W/COBBLES/BOULDERS	Surface	61
		Z	S	Z-CLAY & GRAVEL S-SANDY	61	96
U		C		U-BLUE C-CLAY	96	108
		Z	Z	Z-CLAY & GRAVEL Z-W/COBBLES/BOULDERS	108	124
		L		L-LIMESTONE/DOLOMITE	124	241

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97#/FT ASTM A53B WHEATLAND WELDED	Surface	124
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

137 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS	583	04-29-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MW		04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		125	Septic or Holding, or POWTS Tank		108

Comment:

Created On: 04-29-2026 Updated On: 05-29-2026 Review Status: APPROVED