# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACM951

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: KEMIS, BRAD | Phone # |
| Mailing Address: 445 ALEX CT | |
| City: HUDSON | State: WI — Zip Code: 54016 |

| County | Co. Permit # | Notification # | Completed |
|---|---|---|---|
| Polk | | 10248054201 | 04-30-2026 |

| Well Constructor (Business Name) | Lic. # | Facility ID # (Public Wells) |
|---|---|---|
| TIM BUTTERFIELD DRILLING INC | 6900 | |

Address: 395 REED ST
SOMERSET WI 54025

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.4

**3. Well serves** 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**1. Well Location**

Fire # (if avail.): 2730

Town of FARMINGTON

Street Address or Road Name and Number: 51ST ST

| Subdivision Name | Lot # | Block # |
|---|---|---|
| PRAIRIE VIEW HILLS | 18 | |

Latitude / Longitude in Decimal Degree (DD): 45.2824 °N -92.7197 °W
Method Code: SCR002

| SW | SE | Section | Township | Range |
|---|---|---|---|---|
| or Govt Lot # | | 4 | 32 N | 19 W |

**2. Well Type** New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 240 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | Yes |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| | | Y | | Y-SAND & GRAVEL | Surface | 105 |
| | | C | | C-CLAY | 105 | 210 |
| | | L | | L-LIMESTONE/DOLOMITE | 210 | 240 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | NEW P&E BLK WELDED 18.97 LB/FT ASTM A53 NUCOR | Surface | 210 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | 20 | 2 S |

**9. Static Water Level**
140 ft. below ground surface

**10. Pump Test**
Pumping level 187 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

**11. Well Is**
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| TB | 6901 | 04-30-2026 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| NS | 8774 | 04-30-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS holding component (also known as holding tank) | > | 25 | POWTS dispersal component (soil absorption unit or mound) | > | 50 |

Comment:

Created On: 04-29-2026 Updated On: 05-29-2026 Review Status: APPROVED