Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM956

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KOMATZ, KARI	Phone #
Mailing Address: 1876 DOVER DR	
City: FRIENDSHIP	State: WI — Zip Code: 53934
County: Adams	Co. Permit #: — Notification #: 10223405401 — Completed: 04-14-2026
Well Constructor (Business Name): HEZPAZ ENTERPRIZES	Lic. #: 8094 — Facility ID # (Public Wells):
Address: 3898 5TH DR, WISCONSIN DELLS WI 53965	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of QUINCY	Fire # (if avail.): 1876
Street Address or Road Name and Number: DOVER DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.93044 °N -89.9323 °W	Method Code: SCR002
SE NW or Govt Lot #: — Section: 20 — Township: 17 N — Range: 5 E	

2. Well Type Replacement

of previous unique well # LB322 constructed in 1998

Reason for replaced or reconstructed well ?
OLD WELL CASING RUSTED

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	33
1.25	33	36

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	N	S		Y-YELLOW N-FINE S-SAND	Surface	8
T	M	S		T-TAN/BROWN M-MEDIUM S-SAND	8	36

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND A53 SCH 40 T&C	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	SSCSWR #10 SLOT W/ KPACKER	33	36

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	33	0.5 S

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface
Pumping at 7.5 GP M for 1.5 Hrs.
Pumping Method ? Test Pump

11. Well Is

15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HZ	3851	04-29-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		37	POWTS dispersal component (soil absorption unit or mound)		52

Comment:

Created On: 04-29-2026 Updated On: 10-15-2026 Review Status: APPROVED