

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM956		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner KOMATZ, KARI					Phone #		1. Well Location Fire # (if avail.) 1876					
Mailing Address 1876 DOVER DR												
City FRIENDSHIP			State WI		Zip Code 53934		Town of QUINCY					
Street Address or Road Name and Number					DOVER DR							
County Adams		Co. Permit #		Notification # 10223405401		Completed 04-14-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) HEZPAZ ENTERPRIZES				Lic. # 8094		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code	
Address 3898 5TH DR WISCONSIN DELLS WI 53965				Well Plan Approval #		SE NW Section Township Range		43.93044 °N -89.9323 °W SCR002				
				Approval Date (mm-dd-yyyy)		or Govt Lot # 20		17 N 5 E				
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # LB322 constructed in 1998 Reason for replaced or reconstructed well ? OLD WELL CASING RUSTED						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No		Construction Type Jetted		
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
2		Surface		33		No Rotary - Mud Circulation		No		Y N S Y-YELLOW N-FINE S-SAND Surface 8		
1.25		33		36		No Rotary - Air		No		T M S T-TAN/BROWN M-MEDIUM S-SAND 8 36		
						No Rotary - Air & Foam		No				
						No Drill-Through Casing Hammer						
						No Reverse Rotary						
						No Cable-tool Bit ___ in. dia...		No				
						No Dual Rotary		No				
						No Temp. Outer Casing ___ in. dia						
						No Removed? ___ depth ft. (If NO explain on back side)						
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 15 in. above grade		
2		WHEATLAND A53 SCH 40 T&C				Surface		33		Developed ? Yes		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Disinfected ? Yes		
1.25		SSCSWR #10 SLOT W/ KPACKER				33		36		Capped ? Yes		
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				
GRANULAR BENTONITE				Surface		33		0.5 S				
9. Static Water Level 16 ft. below ground surface												
10. Pump Test Pumping level 25 ft. below surface Pumping at 7.5 GP M for 1.5 Hrs. Pumping Method ? Test Pump												
12. Notified Owner of need to fill & seal ? Yes												
Filled & Sealed Well(s) as needed? Yes												
13. Constructor / Supervisory Driller						Lic #		Date Signed				
HZ						3851		04-29-2026				
Drill Rig Operator						Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		37	POWTS dispersal component (soil absorption unit or mound)		52

Comment:

Created On: 04-29-2026

Updated On: 05-13-2026

Review Status: APPROVED