Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM961

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZEGLER PAUL	Phone #
Mailing Address: 8654N OCHU RD	
City: BASS LAKE	State: WI Zip Code: 54843
County: Sawyer	Co. Permit #:	Notification #: 9972376203	Completed: 04-29-2026
Well Constructor (Business Name): FROEMEL WELL	Lic. #: 6080	Facility ID # (Public Wells):
Address: 15251 W COUNTY B HAYWARD WI 54843-4100	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5

1. Well Location

Town of BASS LAKE			Fire # (if avail.): 8654N
Street Address or Road Name and Number: OCHU RD			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.94866 °N -91.48182 °W			Method Code: GPS008
NE SE or Govt Lot #:	Section: 16	Township: 40 N	Range: 9 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	222

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	20
	Q	S		Q-CAVING S-SAND	20	60
		S	M	S-SAND M-SILTY	60	80
		Y	C	Y-SAND & GRAVEL C-CLAYEY	80	100
		Z	M	Z-CLAY & GRAVEL M-SILTY	100	160
		Z		Z-CLAY & GRAVEL	160	180
		K	M	K-COBBLES/BOULDERS M-SILTY	180	200
		K	N	K-COBBLES/BOULDERS N-W/SANDSTONE	200	215
I	W	N		I-WHITE W-WATER BEARING N-SANDSTONE	215	222

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCA WEILDED ASTM A53B 18.97LB/FT	Surface	218
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	NATURAL	218	222

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		3 S

9. Static Water Level	11. Well Is	
130 ft. below ground surface	24 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 150 ft. below surface	Disinfected ?	Yes
Pumping at 10 GP M for 1 Hrs.	Capped ?	Yes
Pumping Method ? Test Pump		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	7401	04-29-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		110	POWTS dispersal component (soil absorption unit or mound)		130

Comment: WATER SAMPLE WILL BE TAKEN DURING PUMP INSTALL

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	05/29/2026	

Created On: 04-29-2026 Updated On: 05-29-2026 Review Status: APPROVED