Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM966

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RATAJCZAK, BRETT	Phone #
Mailing Address: 11099 WOLFF RD	
City: ARBOR VITAE	State: WI Zip Code: 54568
County: Vilas	Co. Permit #:
Notification #: 10234616501	Completed: 04-22-2026
Well Constructor (Business Name): D&M WATERWORKS LLC	Lic. #: 9148
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.1	

1. Well Location

Town of ARBOR VITAE	Fire # (if avail.): 11099
Street Address or Road Name and Number: WOLFF RD	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.938 °N -89.6955 °W	Method Code: GPS008

SW	NW	Section	Township	Range
or Govt Lot #		24	40 N	6 E

2. Well Type Replacement

of previous unique well # ZJ439 constructed in 2020

Reason for replaced or reconstructed well ?: LOW VOLUME

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	35
S	S-SAND	35	45
G	G-GRAVEL/STONES	45	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM, A53 WELD 19.97LBS; WHEATLAND USA	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	ALLOY SS 12 SLOT	57	60

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 33 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	8520	04-22-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CM	8443	04-22-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	100	Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-29-2026 Updated On: 05-13-2026 Review Status: APPROVED