

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM966		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner RATAJCZAK, BRETT						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 11099 WOLFF RD						Town of ARBOR VITAE						11099	
City ARBOR VITAE						State WI		Zip Code 54568				Street Address or Road Name and Number WOLFF RD	
County Vilas		Co. Permit #		Notification # 10234616501		Completed 04-22-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) D&M WATERWORKS LLC				Lic. # 9148		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.938 °N -89.6955 °W				Method Code GPS008	
Address DBA/RICHARDSON WELL DRLG 10632 STATE HWY 70 WEST MINOCQUA WI 54548				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 24 40 N 6 E		2. Well Type Replacement				of previous unique well # ZJ439 constructed in 2020	
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		Reason for replaced or reconstructed well ? LOW VOLUME							
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled							
Private, potable Drillhole				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
6		Surface		60		No Rotary - Mud Circulation No Yes Rotary - Air No No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y		Y-SAND & GRAVEL				Surface		35					
S		S-SAND				35		45					
G		G-GRAVEL/STONES				45		60					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLK ASTM, A53 WELD 19.97LBS; WHEATLAND USA				Surface		57					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		ALLOY SS 12 SLOT				57		60					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE		Surface				2 S							
9. Static Water Level													
26 ft. below ground surface													
10. Pump Test													
Pumping level 33 ft. below surface													
Pumping at 15 GP M for 2 Hrs.													
Pumping Method ? Test Pump													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
TF				8520		04-22-2026							
Drill Rig Operator				Lic or Reg #		Date Signed							
CM				8443		04-22-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	100	Septic or Holding, or POWTS Tank	=	90

Comment:

Created On: 04-29-2026

Updated On: 05-13-2026

Review Status: APPROVED