Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM974

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PHIL STRINGER			Phone #
Mailing Address: 1382 CHERRY HILL RD			
City: MENDOTA HEIGHTS	State: MN	Zip Code: 55118	
County: Burnett	Co. Permit #:	Notification #: 10047092504	Completed: 04-29-2026

Well Constructor (Business Name): D M B DRILLING CO INC	Lic. #: 6749	Facility ID # (Public Wells):	
Address: W8760 CTY HWY J SHELL LAKE WI 54871		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of SCOTT
Fire # (if avail.): 29287
Street Address or Road Name and Number: PINE KNOLL RD
Subdivision Name:
Lot #:
Block #:
Latitude / Longitude in Decimal Degree (DD): 45.9722 °N -92.123 °W
Method Code: SCR002

NW	NE	Section	Township	Range
or Govt Lot #		8	40 N	14 W

2. Well Type New Well
of previous unique well #
constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	Y		T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL	Surface	60
R	H	Z	Z	R-RED H-HARD/FIRM Z-CLAY & GRAVEL Z-W/COBBLES/BOULDERS	60	120
T	E	Y		T-TAN/BROWN E-CLEAN Y-SAND & GRAVEL	120	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	CRESTLINE PVC SDR 21 SOLVENT JOINT	Surface	136
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	ATTACHED STAINLESS STEEL 18 SLOT	136	140

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	133	13 S
RED FLINT # 40	133	140	6 S

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DMB	6242	04-29-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SRB	9030	04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45

Comment:

Created On: 04-29-2026 Updated On: 05-29-2026 Review Status: APPROVED