

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM974				Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PHIL STRINGER						Phone #						1. Well Location				Fire # (if avail.)							
Mailing Address 1382 CHERRY HILL RD												Town of SCOTT				29287							
City MENDOTA HEIGHTS						State MN		Zip Code 55118						Street Address or Road Name and Number				PINE KNOLL RD					
County Burnett		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #									
				10047092504		04-29-2026																	
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code							
D M B DRILLING CO INC						6749						45.9722 °N -92.123 °W				SCR002							
Address W8760 CTY HWY J SHELL LAKE WI 54871						Well Plan Approval #				NW NE		Section		Township		Range							
						Approval Date (mm-dd-yyyy)				or Govt Lot #		8		40 N		14 W							
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?													
						0.4																	
3. Well serves # of HOME						Hicap Well ?				No				Construction Type		Drilled							
Private,potable						Hicap Property ?				No													
Heat Exchange ___ # of drillholes						Hicap Potable ?				No													
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
8.75		Surface		140		Yes Rotary - Mud Circulation				No		T M Y		T-TAN/BROWN M-MEDIUM Y-SAND & GRAVEL				Surface		60			
						No Rotary - Air				No		R H Z Z		R-RED H-HARD/FIRM Z-CLAY & GRAVEL Z-W/COBBLES/BOULDERS				60		120			
						No Rotary - Air & Foam				No		T E Y		T-TAN/BROWN E-CLEAN Y-SAND & GRAVEL				120		140			
						No Drill-Through Casing Hammer																	
						No Reverse Rotary																	
						No Cable-tool Bit ___in. dia...				No													
						No Dual Rotary				No													
						No Temp. Outer Casing ___in. dia																	
						No Removed? ___depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				18 in. above grade									
5		CRESTLINE PVC SDR 21 SOLVENT JOINT				Surface		136		10. Pump Test				Developed ? Yes									
										Pumping level 65 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 20 GP M for 1 Hrs.				Capped ? Yes									
4		ATTACHED STAINLESS STEEL 18 SLOT				136		140		Pumping Method ? Airlift													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No									
Method TREMIE PIPE - PUMPED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No													
EZ SEAL				Surface		133		13 S															
RED FLINT # 40				133		140		6 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed							
DMB														6242		04-29-2026							
Drill Rig Operator														Lic or Reg #		Date Signed							
SRB														9030		04-29-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45

Comment:

Created On: 04-29-2026

Updated On: 05-29-2026

Review Status: APPROVED