Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM977

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REDLEAF HOMES/SAFRANEK	Phone #: (262)599-8061
Mailing Address: 17035 W GREENFIELD AVE	
City: NEW BERLIN	State: WI / Zip Code: 53151
County: Waukesha	Co. Permit #:
Notification #: 10248222201	Completed: 04-29-2026
Well Constructor (Business Name): HERR WELL DRILLING INC	Lic. #: 672
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: W295 HERR RD, DOUSMAN WI 53118-9407	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.5	

1. Well Location

Village of SUMMIT	Fire # (if avail.): 929
Street Address or Road Name and Number: N GENESEE WOODS ROAD	
Subdivision Name:	Lot #: / Block #:
Latitude / Longitude in Decimal Degree (DD): 43.0436 °N -88.476 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 27 / Township: 7 N / Range: 17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	33

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
F	F-FILL	Surface	5
Y	Y-SAND & GRAVEL	5	33

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS PER FT NEW STEEL PLAIN END ASTM A53 GRADE B NUCOR TUBULAR 2660 PSI	Surface	30
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPIC, STAINLESS STEEL, 18-SLOT, WITH PACKER AND NIPPLE INSTALLED	30	33

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 30 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

NONE

Filled & Sealed Well(s) as needed? Yes

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
ALO	6666	04-29-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
NSD	8132	04-29-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		120	Septic or Holding, or POWTS Tank		85

Comment:

Created On: 04-29-2026 Updated On: 05-29-2026 Review Status: APPROVED