Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM980

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRUCE MAUER			Phone #
Mailing Address: 24792 CLAM LAKE DR			
City: SIREN	State: WI	Zip Code: 54872	
County: Burnett	Co. Permit #:	Notification #: 10248745401	Completed: 04-29-2026

Well Constructor (Business Name): D M B DRILLING CO INC	Lic. #: 6749	Facility ID # (Public Wells):	
Address: W8760 CTY HWY J SHELL LAKE WI 54871		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.7	

1. Well Location

Town of MEENON				Fire # (if avail.): 24859
Street Address or Road Name and Number: CLAM LAKE DRIVE				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.8182 °N -92.3234 °W				Method Code: SCR002
SW SW or Govt Lot #:	Section: 35	Township: 39 N	Range: 16 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	30

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S	T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	30

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	CRESTLINE PVC SDR 21 SOLVENT JOINT	Surface	26
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	TELESCOPE STAINLESS STEEL 12 SLOT	26	30

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	24	3 S
RED FLINT # 20	24	30	6 S

9. Static Water Level
2 ft. below ground surface

10. Pump Test
Pumping level 8 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DMB	6242	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SRB	9030	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		75

Comment:

Created On: 04-30-2026 Updated On: 05-29-2026 Review Status: APPROVED