

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM986		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner RAMIREZ, DAYTON						Phone #		1. Well Location				Fire # (if avail.)													
Mailing Address S12748 COUNTY LINE RD						Town of SPRING GREEN				S12584															
City LONE ROCK						State WI		Zip Code 53556				Street Address or Road Name and Number TIMBER TRAIL													
County Sauk		Co. Permit #		Notification # 10249167101		Completed 04-29-2026		Subdivision Name			Lot #		Block #												
Well Constructor (Business Name) SAM'S WELL DRILLING				Lic. # 370		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.17728 °N -90.11038 °W			Method Code GPS008												
Address 150 RANDOLPH STREET RANDOLPH WI 53956				Well Plan Approval #		SW		SW		Section 11		Township 8 N		Range 3 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		2. Well Type New Well of previous unique well # constructed in																			
3. Well serves 1 # of HOME Private, potable Heat Exchange ____ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled																	
						Hicap Property ? No																			
						Hicap Potable ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method																									
Dia. (in.) 6		From (ft.) Surface		To (ft.) 102		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
						<u>No</u> Rotary - Mud Circulation		<u>No</u>		X Y		X- LENSED/STREAKED/LAYERED Y-SAND & GRAVEL		Surface		80									
						<u>No</u> Rotary - Air		<u>No</u>		A S		A-COARSE S-SAND		80		97									
						<u>No</u> Rotary - Air & Foam		<u>No</u>		A Y		A-COARSE Y-SAND & GRAVEL		97		102									
						<u>Yes</u> Drill-Through Casing Hammer																			
						<u>No</u> Reverse Rotary																			
						<u>No</u> Cable-tool Bit ____ in. dia...		<u>No</u>																	
						<u>No</u> Dual Rotary		<u>No</u>																	
						<u>No</u> Temp. Outer Casing ____ in. dia																			
						<u>No</u> Removed? ____ depth ft. (If NO explain on back side)																			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				24 in. above grade											
6		STD, BLK, PIPE, .280 WALL, P.E., A53B, KUMAKANG				Surface		98		10. Pump Test				Developed ? Yes											
										Pumping level 60 ft. below surface				Disinfected ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 60 GP M for 1 Hrs.				Capped ? Yes											
5		#15 SLOTTED STAINLESS STEEL TELESCOPING SCREEN W/ K-PACKER				97		102		Pumping Method ? Airlift															
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No											
Method MOUNDED														Filled & Sealed Well(s) as needed? No											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement																	
GRANULAR BENTONITE				Surface				1																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed					
														JVG				6026		04-30-2026					
														Drill Rig Operator				Lic or Reg #		Date Signed					
														KB				7372		04-29-2026					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-30-2026

Updated On: 05-29-2026

Review Status: APPROVED